

Satellite Accumulation Area (SAA)

This Satellite Accumulation Area (SAA) has been approved by EHS for the collection of **HAZARDOUS WASTE** under the following conditions:

1. **Storage limit:**

- The SAA may accumulate as much as 55 gallons of non-acute hazardous waste, and/or 1 qt. liquid or 1 kg solid acute hazardous waste at any one time.

2. **Containers:**

- Compatible with the hazardous waste being stored
- Incompatible wastes, or incompatible wastes and materials, must not be placed in the same container.
TIP: Use secondary containment for liquid

Closed during storage except when:

- Adding or removing or consolidating waste
- Temporary venting is necessary
- To prevent build-up of extreme pressure
- For proper operation of equipment

3. **Label:**

- All hazardous waste containers must be labeled as **HAZARDOUS WASTE**.
- Must indicate the primary hazard (corrosive, reactive, etc.)
- Indicate the approximate percentages of each component totaling 100%

4. **Pick-Up Request:**

- Submit waste pick up request via the EHS website (ehs.ua.edu)

5. **Emergency Preparedness:** All SAAs must have access to a:

- | | |
|-----------------------------------|-------------------------------|
| ▪ Emergency management plan | ▪ Spill kit |
| ▪ Fire alarm & extinguisher | ▪ Communication device |
| ▪ Eyewash station & safety shower | ▪ Maintain appropriate egress |

6. **Exclusions:**

- **NO BIOHAZARD** or **RADIOACTIVE** waste may be mixed with or stored in the SAA unless otherwise approved by EHS. If you have questions regarding your mixed waste, please contact EHS.

In the event of an emergency:

- Alert others in the area and evacuate if necessary
- Phone emergency responders UAPD (205) 348-5454 and EHS (205)348-5905

Lab Hazardous Waste Manager (Please Print): _____

Emergency phone number: _____